



## DECLARATION OF CONFORMITY

WE : DAERYUK CO.,LTD

22-9, Pogong-ro 234beon-gil, Pogok-eup, Cheoin-gu, Yongin-Si, Gyeonggi-Do, Korea

Declare under our own responsibility that the product(s)

Product : Circuit-Breaker for Equipment

Models : DCP 51,52,53BH, DCP 71,72,73BH, DCP 51,52,53BN, DCP 71,72,73BN

- DCP 51,52,53BH/BN : AC 240/415V, 1.5/1.5kA (0.3A, 0.5A, 0.75A, 1A ~ 50A)
- DCP 71,72,73BH/BN : AC 240/415V, 1.5/1.5kA (51A ~ 60A)
- Mode of Tripping : HM (Hydraulic Magnetic)
- Method of Operation : S-type
- Tripping Characteristics : (I, H, M, L)
- Auxiliary Circuit : (S, W, E, C, F)

to which this declaration refers conform to :

STANDARDS OR NORMATIVE DOCUMENTS :

Circuit-breakers for equipment (CBE)

General Rules

IEC(EN) 60934 : 2019

Electrical accessories - Circuit-breakers for over current  
protection for household and similar installations -  
Part 1 : Circuit-breakers for a.c. operation

IEC(EN) 60898-1 : 2015

following the provisions of the Low - Voltage Directive 2006/95/EC

The CE mark on the products and/or their packaging

signifies that DAERYUK CO.,LTD holds the reference

technical file available to the European Union authorities

DATE : 15 January 2024

Signatures :



President

I.S. JO

Technical Manager



DAERYUK CO.,LTD.