

# Certificate of Compliance

**Certificate:** 1633264

**Master Contract:** 175487 (LR114269)

**Project:** 80010376

**Date Issued:** 2019-07-19

**Issued to:** Daeryuk Co Ltd  
530 Samgae-Ri Pogok-Myun  
Kyonggi-Do, 449-810  
South Korea  
**Attention:** Mr. Youngnin Cheon

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** *Hannah Deng*  
Hannah Deng

## **PRODUCTS**

CLASS - 3215 30 - SUPPLEMENTARY PROTECTORS – Component Acceptance Program

### **Part A (Design 1)**

- Series DCP-3\*PS/SS (with suffixes), 1-2 and 3-pole, 1-30A, 250V ac, 50/60Hz,  
Application Codes: TC2, OL0, SC: C1, 1kA, 250V ac (General Use, 4In fuse)

### **Part B (Design 2):**

- Series DCP-3\*PS/SS/TS/PP (with suffixes), 1- pole, 1-30A, 250V ac, 50/60 Hz, 65V dc; 2 and 3- poles, 1-25A, 250V ac, 50/60 Hz, 65V dc;  
Application Codes:  
1-30A, 250Vac, 1-pole: Terminals Type PS/SS/TS/PP, TC0, OL1, SC: U3, 1kA, 250V ac, SC: U3, 1kA, 65V dc;  
1-25A, 250V ac, 2 and 3 - poles, Terminals Type PS/SS/TS/PP, TC0, OL1, SC: U3, 1kA, 250V ac, SC: U3, 1kA, 65V dc;

### **Part C:**

- Series DCP-5\*BU (with suffixes), 1- and 2-pole, 5-50A, 250V ac, 50/60 Hz.  
Application Code: TC2, OL0, SC: 1.5kA, C1 250V ac (General Use, 4In Series fuse)



**Certificate:** 1633264  
**Project:** 80010376

**Master Contract:** 175487  
**Date Issued:** 2019-07-19

Notes:

1. These devices are accepted as components, for use only in other Certified equipment where the suitability of the combination is to be determined by the CSA International.
2. Suffix numbers are added to catalogue type designation to indicate the current rating.
3. The asterisk in the catalogue type designation is replaced by a number to indicate the number of poles.
4. These devices are not suitable for reversed "Line" and "Load" connections.
5. See product Application codes for short circuit withstand ratings.
6. All terminal types are suitable for factory wiring only.
7. Series DCP-3\* are evaluated with Auxiliary Switches rated 3A, 250v ac.

**APPLICABLE REQUIREMENTS**

CSA Std. C22.2 No.	235-04	-	Supplementary Protectors.
Acceptance Service No.	32	-	Component Acceptance Service for Supplementary Protectors for use in Electrical and Electronic Equipment
Certification Notice:	N04-042	-	Publication of New Edition of CSA Standard C22.2 No. 235-04



## *Supplement to Certificate of Compliance*

**Certificate:** 1633264

**Master Contract:** 175487

*The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

<b>Project</b>	<b>Date</b>	<b>Description</b>
80010376	July 19, 2019	Update Report 1633264 for DCP-3*PS/SS and DCP-5*BU series to Change plastics material of Dust Cover/Handle, and change name from “Handle Spacer” to “Handle Guide”.
1785358	July 12, 2006	To cover TC0, OL1, U3 Classification for DCP-3*PS/SS/TS/PP, 1-30A, 250V ac, 65 V dc; Evaluation to U1a Classification.
1633264	January 18, 2005	Products re-listed under CSA Components Acceptance Program.

### **History**

LR114269-1, May 18/99 Supplementary Protectors, Series DCP-3\*PP/SS and DCP-5\*BU.